


***Gemaire Distributors
HVAC Load Analysis***

for

Gemaire Distributors
659 NW Enterprise Drive
Port St. Lucie, Florida



CHVAC COMMERCIAL
HVAC LOADS



Prepared By:

Eric J. Svoboda, PE
Fort Pierce Engineering, Inc.
315 South 7th Street
Fort Pierce, FL 34950
772-672-4636
Thursday, September 2, 2021



General Project Data Input

General Project Information

Project file name: Gemaire Distributors Heat Load.CH8
Project title: Gemaire Distributors
Designed by: Eric J. Svoboda, PE
Project date: Monday, July 07, 2008
Weather reference city: FORT PIERCE, FLORIDA, USA
Client name: Gemaire Distributors
Client address: 659 NW Enterprise Drive
Client city: Port St. Lucie, Florida
Company name: Fort Pierce Engineering, Inc.
Company representative: Eric J. Svoboda, PE
Company address: 315 South 7th Street
Company city: Fort Pierce, FL 34950
Company phone: 772-672-4636
Company fax: 772-672-4637

Barometric pressure: 29.894 in.Hg.
Altitude: 25 feet
Latitude: 27 Degrees
Mean daily temperature range: 15 Degrees
Starting & ending time for HVAC load calculations: 7am - 10pm
Number of unique rooms in this project: 2

Building Default Values

Calculations performed: Both heating and cooling loads
Lighting requirements: 2.00 Watts per square foot
Equipment requirements: 1.00 Watts per square foot
People sensible load multiplier: 250 Btuh per person
People latent load multiplier: 200 Btuh per person
Room sensible safety factor: 0 %
Room latent safety factor: 0 %
Room heating safety factor: 0 %
People diversity factor: 100 %
Lighting profile number: 0
Equipment profile number: 0
People profile number: 0
Building default ceiling height: 10.00 feet
Building default wall height: 14.00 feet

Internal Operating Load Profiles (C = 100)

	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr	hr
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
2	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
3	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
4	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
5	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
6	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
7	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
8	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
9	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
10	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C



General Project Data Input (cont'd)

Building-Level Design Conditions

Design Month	Outdoor Dry Bulb	Outdoor Wet Bulb	Indoor Rel.Hum	Indoor Dry Bulb	Grains Diff	In/Outdoor Correction
August	95	80	50%	75	66.33	6
Winter	42			75		

Master Roofs

Roof No.	ASHRAE Roof#	Roof U-Fac	Dark Color	Susp. Ceil
1	1	0.050	No	No
Roof #1 Description: Metal Roof, R-20				

Master Walls

Wall No.	ASHRAE Group	Wall U-Fac	Wall Color
1	D	0.086	D
Wall #1 Description: Frame wall, wood/insulated metal framing, face brick exterior, interior finish, R-11 batt insulation			

Master Partitions

Partition No.	Partition U-Factor	Cool T-D	Heat T-D
1	0.073	0	0
Partition #1 Description: Frame partition, hollow metal framing, siding exterior, interior finish, R-13 batt insulation			



Building Summary Loads

Building peaks in August at 2pm.

Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	252	416	28.02	0	565	565	9.27
Wall	0	0	0.00	0	0	0	0.00
Glass	0	0	0.00	0	0	0	0.00
Floor Slab	0	0	0.00	0	0	0	0.00
Skin Loads		416	28.02	0	565	565	9.27
Lighting	504	0	0.00	0	1,720	1,720	28.22
Equipment	252	0	0.00	0	860	860	14.11
Pool Latent	0	0	0.00	0	0	0	0.00
People	2	0	0.00	400	500	900	14.77
Partition	448	0	0.00	0	0	0	0.00
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	30	0	0.00	1,352	659	2,011	33.01
Heat. Vent.	30	1,068	71.98	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	38	38	0.63
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	0	0	0.00
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	0	0.00	0	0	0	0.00
Return Duct	0	0	0.00	0	0	0	0.00
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
Building Totals		1,484	100.00	1,752	4,342	6,094	100.00

Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Ventilation	1,068	71.98	1,352	659	2,011	33.01
Infiltration	0	0.00	0	0	0	0.00
Pretreated Air	0	0.00	0	0	0	0.00
Room Loads	416	28.02	400	3,644	4,044	66.37
Plenum Loads	0	0.00	0	0	0	0.00
Fan/Duct/Misc Loads	0	0.00	0	38	38	0.63
Building Totals	1,484	100.00	1,752	4,342	6,094	100.00

Check Figures

Total Building Supply Air (based on a 21° TD): 160 CFM
Total Building Vent. Air (18.80% of Supply): 30 CFM

Total Conditioned Air Space: 252 Sq.ft
Supply Air Per Unit Area: 0.6331 CFM/Sq.ft
Area Per Cooling Capacity: 496.2 Sq.ft/Ton
Cooling Capacity Per Area: 0.0020 Tons/Sq.ft
Heating Capacity Per Area: 5.89 Btuh/Sq.ft

Total Heating Required With Outside Air: 1,484 Btuh
Total Cooling Required With Outside Air: 0.51 Tons



Air Handler #1 - AHU 1 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
1	Office 1 2pm August	126 1 1,260	208 15 0.12	1,822 80 0.63	200 0 0	Direct 15 15	Direct 15 15
2	Office 2 2pm August	126 1 1,260	208 15 0.12	1,822 80 0.63	200 0 0	Direct 15 15	Direct 15 15
	Room Peak Totals:	252	416	3,644	400		
	Total Rooms: 2	2	30	160	0	30	30
	Unique Rooms: 2	2,520	0.12	0.63	0	30	30



Air Handler #1 - AHU 1 - Total Load Summary

Air Handler Description: AHU 1 Constant Volume - Proportion
Supply Air Fan: Draw-Thru with program estimated horsepower of 0.02 HP
Fan Input: 0% motor and fan efficiency with 0 in. water across the fan
Sensible Heat Ratio: 0.90 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 2pm in August.
Outdoor Conditions: Clg: 95° DB, 80° WB, 131.77 grains, Htg: 42° DB
Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 75° DB

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Room Space sensible loss:	416 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	1,068 Btuh	30 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		1,484 Btuh

Heating Supply Air: $416 / (.999 \times 1.08 \times 13) =$	30 CFM
Winter Vent Outside Air (100.0% of supply) =	30 CFM

Room space sensible gain:	3,644 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	38 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		3,682 Btuh

Cooling Supply Air: $3,682 / (.999 \times 1.1 \times 21) =$	160 CFM
Summer Vent Outside Air (18.8% of supply) =	30 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	659 Btuh	30 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		659 Btuh
Total sensible gain on air handling system:		4,342 Btuh

Room space latent gain:	400 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	1,352 Btuh	
Total latent gain on air handling system:		1,752 Btuh
Total system sensible and latent gain:		6,094 Btuh

Check Figures

Total Air Handler Supply Air (based on a 21° TD):	160 CFM
Total Air Handler Vent. Air (18.80% of Supply):	30 CFM
Total Conditioned Air Space:	252 Sq.ft
Supply Air Per Unit Area:	0.6331 CFM/Sq.ft
Area Per Cooling Capacity:	496.2 Sq.ft/Ton
Cooling Capacity Per Area:	0.0020 Tons/Sq.ft
Heating Capacity Per Area:	5.89 Btuh/Sq.ft
Total Heating Required With Outside Air:	1,484 Btuh
Total Cooling Required With Outside Air:	0.51 Tons