

**K.HOVNANIAN COMPANIES, LLC**  
90 MATAWAN ROAD, MATAWAN, NJ 07747  
TEL: (732) 383-2200 KHOV.COM

City of Port St. Lucie Building Department  
121 S.W. Port St. Lucie Blvd.  
Port St. Lucie, FL 34984

September 13, 2022

Community Name: **Aspire at East Lake**  
Location: **2388 SE Union Park Drive**  
**Port St. Lucie, Florida**  
Plan Name: **Lot 12, Block 51 - Stetson**  
Subject: **RE: Permit No. 2213872**

To Whom it May Concern:

The purpose of this correspondence is to advise that we have updated the architectural plans for the above referenced home and permit number. All plan updates are clouded and tagged with a Delta 4. Please refer to a complete list of plan updates below.

**Sheet CS1.1**

- Updated Code Conformance Notes and Area and Volume Computation to reflect full plan conversion to a Business Use Group.

**Sheet LS-1**

- Updated Life Safety Plan to include the maximum travel distance at 1<sup>st</sup> and 2<sup>nd</sup> floor plans.
- The Front Door and Display Center Door have been identified as the two means of egress.
- Exterior ramps and accessible thresholds have been added to the Front Door, Display Dining Area sliding glass door, and the Display Center exterior door.
- Flipped the hinged side of the Display Center exterior door.
- Removed door and provided accessible ramp between HovHall and Office 1.
- Added fire extinguisher location at Display Dining Area.
- Relocated emergency light from Office 1 to HovHall.
- Added exit sign at Display Kitchen leading to HovHall.
- Added exit sign at the bottom of 1<sup>st</sup> floor stair.
- Added exit sign at front door exit.
- Added emergency light facing Display Dining Area.
- Added emergency light and exit sign to 2<sup>nd</sup> floor. Hall near stair.

**Sheet A-200**

- Exterior ramps and accessible thresholds have been added to the Front Door, Display Dining Area sliding glass door, and the Display Center exterior door.
- Flipped the hinged side of the Display Center exterior door.
- Removed door and provided accessible ramp between HovHall and Office 1.
- Added Level Change detail identifying different threshold types.

**Sheet A-500**


- Flipped the hinged side of the Display Center exterior door.

**Sheet E-100**

- Relocated emergency light from Office 1 to HovHall.
- Added exit sign at Display Kitchen leading to HovHall.
- Added exit sign at the bottom of 1<sup>st</sup> flr. stair.
- Added exit sign at front door exit.
- Added emergency light facing Display Dining Area.
- Added emergency light and exit sign to 2<sup>nd</sup> flr. Hall near stair.

Feel free to contact me should you have any questions or require additional information.

Regards,



Dawn Boggio Korbela, RA  
Director, Corporate Product Development  
Florida Architectural License Number: 94880

