

Mission:

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



Ron DeSantis
Governor

Joseph A. Ladapo, MD, PhD
State Surgeon General

Vision: To be the Healthiest State in the Nation

January 31, 2023

Facility Name:	Bristol at Wylder Amenity Center Pool (56-60-2631153)		
Facility Address:	6220 Sweetwood Drive, Port St Lucie, FL 34953		
Applicant Name:	Midway Glade Developers		
Applicant Address:	7807 Baymeadows Road E Suite 205, Jacksonville, FL 32256		
Public Pool Permit Application received on:	01/13/2023	Pool <input checked="" type="checkbox"/>	Spa <input type="checkbox"/> IWF <input type="checkbox"/> Other <input type="checkbox"/>

RE: Public Pool Plans Compliance with Critical Health and Safety checklist

Dear Applicant:

Review of the submitted operation permit application revealed:

Compliance, provided items are addressed ☒, Non-Compliance ☐,
with the following items included in the enclosed Critical Health and Safety checklist:

Y <input type="checkbox"/> N <input checked="" type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.13	The rate of flow indicator shall be properly sized for the design flow rate and shall be capable of measuring from one half to at least one and one-half times the design flow rate. SHEET I1.1, POOL EQUIPMENT LIST, BLUE-WHITE, 4", MODEL F30400P, 75GPM – 420GPM RANGE, 168GPM – 503GPM REQUIRED, FLOW METER UNDERSIZED
---	--------------	--

Please see enclosed checklist, all items marked N and highlighted must be addressed or corrected to pass final DOH construction operation permit inspection.

Any changes to application and/or plans made after they are deemed compliant by the Florida Department of Health and approved by the jurisdictional building department will require submittal of the revised plans and application for approval by both Departments.

At least two weeks prior to the estimated date that the pool will be ready for the construction inspection, the pool contractor must contact the DOH-Regional contact at DOHPoolTeam@flhealth.gov to schedule the initial inspection. Prior to issuing your operating permit, the local county Health Department will require:

1. A set of plans and specifications as approved for construction by the local building authority as well as a copy of DH 4159 and DH 4157 for each body of water.
2. A copy of the final inspection from the local building authority as defined in Section 553.79(11), Florida Statutes.
3. The annual operating permit fee.

Any Critical Health and Safety Code inconsistencies found at the time of final inspection will prevent issuance of operating permit by the Florida Department of Health. Thank you for your cooperation in this matter. Please contact our team at DOHPoolTeam@flhealth.gov with any questions you may have.

Florida Department of Health

Division of Disease Control & Health Protection • Bureau of Environmental Health
4052 Bald Cypress Way, Bin A-08 • Tallahassee, FL 32399

FloridaHealth.gov



Accredited Health Department
Public Health Accreditation Board

Brystol at Wylder Amenity Center Pool (56-60-2631153)

Page Two

January 31, 2023

Sincerely,



Alison DeVore

Environmental Consultant

Bureau of Environmental Health, Water Programs

cc: David.Koerner@flhealth.gov; Joanne.Evans@flhealth.gov; Melanie.Vance@flhealth.gov;
Veronica.Fitzsimmons@flhealth.gov; DOHPoolTeam@flhealth.gov; Terrance.Marsh@flhealth.gov; Bob.Vincent@flhealth.gov;
mtaylor@greenpointellc.com; planreview@cityofpsl.com; HWB@wetengineering.net; jel@wetengineering.net;
ws@wetengineering.net;

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version 12/31/2020 Effective (1/1/2021) 1/19/2022
update

Project:	Bristol at Wylder Amenity Center Pool	County:	St. Lucie	Date:	1/31/2023
Permit #:	56-60-2631153	Original	<input checked="" type="checkbox"/>	Revision	<input type="checkbox"/>
Engineer:	WET Engineering	Reviewed by:	T. Marsh, A. DeVore, S. Sombutmai, &/or A. Flanery		

Items needing correction or clarification are marked by an "N" beside the appropriate section number of the Florida Administrative Code citation (Current 64E-9, FAC, or current FBC 454.1). We have left the 64E-9 requirements in this checklist because they are critical for public health and therefore the pool will be checked for these items by the County Health Department at the first operating permit inspection after the Building Official's approval of the construction.

COMPLIANCE:	FLORIDA BUILDING CODE, FLORIDA STATUTES, OR FLORIDA ADMINISTRATIVE CODE:	DETAILS:
SUBMITTAL REQUIREMENTS		
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	514.031(1)(a)	Plans review fees received as required by Florida Statute 514.031(1)(a)
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	514.031(1)(a)	A current version of application (DH 4159) for approval of swimming pool plans received.
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	514.031(1)(a)	<p>A set of construction plans that include the following:</p> <ol style="list-style-type: none"> 1. A description of the structure, its appurtenances, and its operation. 2. A description of the source or sources of water supply, and the amount and quality of water available and intended to be used. 3. The method and manner of water purification, treatment, disinfection, and heating. 4. The safety equipment and standards to be used. 5. A copy of the final inspection from the local enforcement agency as defined in s. 553.71. 6. Any other pertinent information deemed necessary by the department.
SIZING REQUIREMENTS		
REFERENCE	454.1.1.1	<p>The pools provided at a transient facility shall be able to accommodate one bather per five living units, while the bathing load at a non-transient facility shall be at least one bather per seven living units. Recreational vehicle sites, campsites and boat slips designated for liveaboards shall be considered a transient living unit. For properties with multiple pools, this requirement includes the cumulative total bathing load of all swimming pools, spas, wading pools and interactive water features. The bathing load for conventional swimming pools, wading pools, interactive water features, water activity pools and special purpose pools shall be computed either on the basis of one person per 5 gpm (0.32 L/s) of recirculation flow, or one person per each 20 square feet (1.9 m²) of surface area, whichever is less. The bathing load for spa type pools shall be based on one person per each 10 square feet (0.9 m²) of surface area. <u>All other types of projects</u> shall be sized according to the anticipated bathing load and proposed uses.</p> <p>FOR CALCULATION STEPS AND EXAMPLES OF SIZING CALCULATIONS FOR TRANSIENT OR NON-TRANSIENT FACILITIES PLEASE SEE APPENDIX A.</p>
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.1.1- Non-Transient	<p>Non-Transient Calculations:</p> <p># of Living Units / 7 = Minimum Required Bather Load (For All Pools, Spas, Etc. Combined)</p> <p>Required Bather Load x 5 Gallons Per Minute Per Bather = Minimum Required Flowrate (For All Pools, Spas, Etc. Combined)</p> <p>Required Bather Load x 20 sq. ft. Surface Area = Minimum Required Square Footage (For All Pools, Wade & IWF. Combined)</p> <p>Required Bather Load x 10 sq. ft. Surface Area = Minimum Required Square Footage (For only Spa pools)</p> <p>466 UNITS ÷ 7 = 67 MINIMUM BATHERS, 335GPM AND 1,340 SQ.FT. SURFACE AREA REQUIRED, 67 BATHERS, 335GPM AND 2,494 SQ.FT. PROVIDED</p>
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.1.1	Bathing load: The bathing load is computed on the basis of 1 person per each 5 gpm of water recirculated. 335GPM ÷ 5 = 67 BATHERS
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.1.1	Where a pool's turnover rate is calculated to be less than 3 hours, that pool shall comply with Section 454.1.7.9 for automated controllers. 58,860 GALLS ÷ 335GPM ÷ 60 = 2.92 HOURS, SHEET M4.2, FILTER EQUIPMENT LIST, HAYWARD, CAT2000 pH/ORP CONTROLLER
CONSTRUCTION STANDARDS		
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.1	Pools shall be constructed of concrete or other impervious and structurally rigid material. All pools shall be watertight, shall be free from structural cracks and shall have a nontoxic smooth and slip-resistant finish. All materials shall be installed in accordance with manufacturer's specifications unless such specifications violate Chapter 64E-9, Florida

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Bristol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

		Administrative Code, rule requirements or the approval criteria of NSF/ANSI Standard 50 or NSF/ANSI Standard 60. SHEET S1.0, STRUCTURAL – CONCRETE NOTES
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.1(a)& 454.1.2.4	Floors and walls shall be white or pastel in color and shall have the characteristics of reflecting rather than absorbing light. Pool floors and walls shall be white or light pastel in color and shall have the characteristic of reflecting rather than absorbing light. The interior finish coating floors and walls shall be comprised of a non-pigmented white cementitious binder component together with a sand/aggregate component. The finish coating shall have a dry lightness level (CIE L value) of 80.0 or greater and a wet luminous reflectance value (CIE Y value) of 50.0 or greater, as determined by test results provided by the manufacturer, utilizing testing methodology from American Standard ASTM D4086, ASTM E1477, ASTM E1347. Pools constructed of fiberglass, thermoplastic, or stainless steel shall be subject to the same interior finish color requirements. SHEET I1.0, POOL NOTES #13
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.1(a)	Horizontal tile used in less than 5' (1,524 mm) of water must be slip resistant. (FBC Definitions: "Slip resistant" means having a textured surface which is not conducive to slipping under contact of bare feet unlike glazed tile or masonry terrazzo and nontextured plastic materials. Manufactured surface products shall be designated by the manufacturer as suitable for walking surfaces in wet areas.) SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.1(a)& 454.1.2.4	A minimum 4-inch (102 mm) tile line, each tile a minimum size of 1 inch (25 mm) on all sides, shall be installed at the water line, but shall not exceed 12 inches (305 mm) in height if a dark color is used. Gutter type pools may substitute 2-inch (51 mm) tile, each a minimum size of 1-inch (25 mm) on all sides, along the pool wall edge of the gutter lip. SHEET M1.1, POOL SECTION
ENSURE IF APPLICABLE	454.1.2.1(b)(c)	One-inch (25 mm) square tile may be used if the manufacturer has specified the adhesive for use underwater to adhere the type of tile used [vitreous (glass) or ceramic]. Tiles shall not have sharp edges exposed that could cause bather injury. The grout line is allowed to be included when meeting the 1-inch (25 mm) square tile requirements, if the tile is sold and distributed as nominal or trade size tile.

DIMENSION STANDARDS

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.2.2	All pool walls shall have a clearance of 15 feet (4,572 mm) perpendicular to the wall (as measured at design water level from gutter lip to gutter lip, or on skimmer pools, from vertical wall to vertical wall). Offset steps, spa coves, spa pools and wading pools are exempt from this clearance requirement. (FBC Definitions: "Offset" means set back into the deck from the normal pool wall perimeter [three sides must be surrounded by pool deck].) NOTE: Where interior steps protrude into the pool resulting in less than 15 feet (4,572 mm) of clearance from any wall, such protrusion shall not exceed 6 feet (1,828 mm) on any perpendicular line from a tangent to any pool wall from which the steps emanate. SHEET M1.0, POOL GEOMETRY PLAN AND GEOMETRY PLAN NOTES #11
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.2.2	The upper part of pool walls in areas 5 feet deep or less shall be within 5 degrees (4,572 mm) vertical for a minimum depth of 2½ feet (762 mm) from which point the wall may join the floor with a maximum radius equal to the difference between the pool depth and 2½ feet. The upper part of pool walls in areas over 5 feet (1,524 mm) deep shall be within 5 degrees vertical for a minimum depth equal to the pool water depth minus 2½ feet (762 mm) from which point the wall may join the floor with a maximum radius of 2½ feet (762 mm). SHEET M1.1, TYPICAL WALL SECTION - NOTE
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.2.2	Corners shall be a minimum 90-degree angle. SHEET M1.0, POOL GEOMETRY NOTES #8
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.2.2	The corner intersections of walls which protrude or angle into the pool water area shall be rounded with a minimum radius of 2 inches (51 mm). This radius shall be continued through the top of the gutter edge; chamfering is allowed, and pool coping shall not overhang into the pool more than 1½ inches (38 mm) . SHEET M1.0, POOL GEOMETRY NOTES #9 & #7
NOTE:	454.1.2.2.3	The radius of curvature between the floor and walls is excluded from the following two requirements (454.1.2.2.3.1 & 454.1.2.2.3.2). Multiple floor levels in pools are prohibited, however, an area meeting all of the requirements of a sun shelf shall not be considered a violation of this requirement.
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.2.3.1	Floor slope shall be uniform. The floor slope shall be a maximum 1 unit vertical in 10 units horizontal and a minimum of 1 unit vertical in 60 units horizontal in areas 5 feet (1,524 mm) deep or less. SHEET M1.0, POOL GEOMETRY PLAN (1:10, 1:25.5, 1:16)
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.2.4	Pool water depth is at least 3' (914 mm) in shallow area. SHEET M1.0, POOL GEOMETRY PLAN, SHALLOW AREA = 0'0" (ZERO ENTRY)

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.2.4	Pool water depth is at least 4' (1,219 mm) in deep area. SHEET M1.0, POOL GEOMETRY PLAN, DEEP AREA = 5'0"
MARKINGS		
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(2)	Permanent depth markings followed by the appropriate full or abbreviated words "FEET," "FT," or "INCHES," "IN," shall be installed in minimum 4" high (102 mm) numbers and letters on a contrasting background. SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(2)	Depth markers shall indicate actual depth within 3" (76 mm). *Measured at normal operating water level when measured 3' (914 mm) from the pool wall. SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(3)	At a minimum, the markings shall be located on both sides of the pool at the shallow end, slope break, deep-end wall and deep point (if located more than 5' (1,524 mm) from the deep-end wall). SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(3)	Depth markings are visible from inside the pool and from the deck. SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(3)	Maximum perimeter distance between depth markings is 25'. (Pool size and geometry may necessitate additional depth marking placements about all sides of the pool to meet this requirement) SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(4)	When no curb is provided, depth markings are located at or above water level on inside vertical wall and on the deck (within 2' of water edge). SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(4)	When open type gutters are used, depth markers are located on the back of the gutter wall. SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(6)	In areas, not part of an approved diving bowl, tile "NO DIVING" markings are on the curb top or deck within 2' (610 mm) of water edge on each side of pool with a maximum distance between markings of 25' (7,620 mm). SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(6)	The "NO DIVING" markings are at least 4" high (102 mm) high and contrasting; or a 6" (152 mm) tile with min. 4" (102 mm) or larger red international "NO DIVING" symbol. SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(7)	All markings installed on horizontal surfaces have a slip-resistant finish. SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.1(7)	All markings are tile. Markings shall be flush with the surrounding area where placed and recessed if necessary to provide a smooth finish that will avoid creation of an injury hazard to bathers. SHEET M1.0, POOL GEOMETRY PLAN AND DEPTH MARKER DETAILS AND SHEET I1.0, POOL NOTES #1 & #2
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.3	Pools that are not intended to be utilized for officially sanctioned competition may install lap lane markings provided they meet the following criteria: the markings must be 2" - 6" (51 to 152 mm) wide, they must terminate 5' (1524 mm) from the end wall in a "T" with the "T" bar at least 18" (457.2 mm) long, they must be placed at 7' (2,134 mm) intervals on center and be no closer than 4' (1,219 mm) from any side wall, steps or other obstructions. Floating rope lines associated with lap lanes must not obstruct the entrance or exit from the pool and are prohibited when the pool is open for general use. SHEET M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.4	Pools that are not intended for officially sanctioned competition may have 2" - 6" (51 to 152 mm) wide 18" by 18" (457 mm by 457 mm) targets (+) installed on the pool wall. SHEET M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, POOL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	64E-9.008(9)(a)	The bathing load will be posted at the pool as required in the bathing rules. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.5	The lettering for the pool rules sign is at least 1" high (25.4 mm). SHEET I1.0, POOL NOTES #20
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.5	The following rules in BOLD will be posted at or near poolside and will be legible from pool deck:

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
----------	---------------------------------------	-------	-----------

		<p>1. NO FOOD OR BEVERAGES IN THE POOL OR ON POOL WET DECK. COMMERCIALY BOTTLED WATER IN PLASTIC BOTTLES IS ALLOWED ON THE POOL WET DECK FOR POOL PATRON HYDRATION.</p> <p>2. NO GLASS OR ANIMALS IN THE FENCED POOL AREA (OR 50 FEET (15,240 MM) FROM UNFENCED POOL).</p> <p>3. BATHING LOAD: 67 PERSONS.</p> <p>4. POOL HOURS: DAWN A.M. TO DUSK P.M. (DAWN TO DUSK is approved for pool hours if the pool is not certified for night usage)</p> <p>5. SHOWER BEFORE ENTERING.</p> <p>6. “NO DIVING”, in 4-inch (102 mm) letters is required for pools of 200 square feet (18.58 m²) in area or greater without an approved diving well configuration.</p> <p>7. DO NOT SWALLOW THE POOL WATER. (This statement shall be added to signs at pools that conduct alterations as that term is defined)</p> <p>8. “POOL MAXIMUM DEPTH: 5’0” FEET,” in 2-inch (51 mm) letters shall be added to all pool rules by January 1, 2022.</p> <p>SHEET I1.0, POOL NOTES #20</p>
--	--	--

ACCESS		
--------	--	--

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5	All pools shall have a means of access every 75 feet (22,860 mm) of pool perimeter with a minimum of two, located so as to serve both ends of the pool. In addition, an access point shall be provided at the deep portion, if the deep portion is not at one end of the pool. M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.2	Recessed treads shall be installed flush with the wall and shall be a minimum 5 inches (127 mm) wide, 10 inches (254 mm) long, with a maximum vertical distance of 12 inches (305 mm) between treads. M1.0, POOL GEOMETRY PLAN AND SHEET M4.0, RECESSED STEPS AND GRAB RAIL DETAIL
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.3	Stairs shall have a minimum tread width of 10” (254 mm) and a maximum width of 48” (1,219 mm) for a minimum tread length of 24” (610 mm) and a maximum riser height of 10” (254 mm). M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.3	Treads and risers between the top and bottom treads shall be uniform to within ½” (12.7 mm) in width and height. The riser heights shall be measured at the marked step edges and the differences in elevation shall be considered the riser heights. (Exception: Where a gutter is used as a top step, the gutter’s 2” slope from lip to the drain shall be continuous for the full length of the stairs, and the riser from the gutter to the next tread need not be uniform with the remaining risers and treads.) M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.3	The front ¾ to 2 inches (19.1 to 51 mm) of the tread and the top 2 inches (51 mm) of the riser shall be tile, dark in color, contrasting with the interior of the pool. Tile shall be slip resistant. Bullnose tile that is slip resistant may be used when the ¾-inch (19 mm) segment is placed on the tread or horizontal surface and the 2-inch (51 mm) segment is placed on the riser or vertical surface. M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.3	Where the gutter is used as the top step, the tile on the gutter for the width of the steps shall be slip resistant. M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.5	Handrail(s) for the stairs are correct length to mount in deck and bottom step. M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.5	Grabrails must be mounted in the pool deck at each side of recessed steps. M1.0, POOL GEOMETRY PLAN AND SHEET M4.0, RECESSED STEPS AND GRAB RAIL DETAIL
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.5	Handrails and grabrails shall extend between 28 and 40 inches (711 mm and 1,016 mm) above the step edge and deck. GEOMETRY PLAN AND SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.6	Permanent or portable steps, ramps, handrails, lifts or other devices designed to accommodate handicapped individuals in swimming pools may be provided. If provided, lifts mounted into the pool deck shall have a minimum 4-foot-wide (1,219 mm) deck behind the lift mount. M1.0, POOL GEOMETRY PLAN AND SHEET M4.1, ADA LIFT DETAILS
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.6	The pool water area shall be unobstructed by any type structure unless justified by engineering design as a part of the recirculation system. Engineering design and material specifications shall show that such structures will not endanger the pool patron, can be maintained in a sanitary condition and will not create a problem for sanitary maintenance of

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Bristol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

		any part of the pool, pool water, or pool facilities. Structures in accord with the above shall not be located in a diving bowl area or within 15 feet (4,572 mm) of any pool wall. NOTE: Stairs, ladders and ramps, necessary for entrance/exit from the pool are not considered obstructions. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.6(2)	Underwater seat benches may be installed in areas less than 5 feet (1,524 mm) deep. M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, BENCH DETAILS
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.6(2)	Bench seats must be 14 to 18 inches (356 to 457 mm) wide and must have a dark contrasting tile marking on the seat edge extending 2 inches (51 mm) on the horizontal and vertical surface. Tile shall be slip resistant. Bullnose tile may be substituted and installed in accordance with Section 454.1.2.5.3. Vinyl liner, stainless steel and fiberglass pools may use other material for the bench edge marking as detailed in Section 454.1.2.3.1, Item 7, provided the material is permanently secured, dark in color, nonfading and slip resistant M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, BENCH DETAILS
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.6(2)	Benches shall not protrude into the 15-foot (4,572 mm) clearance requirement of Section 454.1.2.6. The bench shall not protrude into the diving bowl. M1.0, POOL GEOMETRY PLAN AND SHEET M1.1, BENCH DETAILS

SUN SHELVES

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.3.5	The following rules must be posted at pools with a sun shelf: 1. "WARNING: DROP-OFF AT SUN-SHELF EDGE IS _____ FEET DEEP" in 4-inch (102 mm) letters. 2. DO NOT PLACE FURNITURE IN POOL, in 1-inch (25.4 mm) letters. SHEET I1.0, POOL NOTES #20
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.5.5	Where stairs are used as an access point between a sun shelf and pool area, a handrail shall be provided. The handrail shall be anchored into the bottom step and the sun shelf floor. (Handrails and grabrails shall extend between 28 and 40 inches (711 mm and 1016 mm) above the sun shelf floor and deck) SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.6 (3)	A sun shelf may be installed in pool areas with no more than 4 feet (1219 mm) of water depth, or less. M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.6 (3)	When the edge of a sun shelf uses stairs as a transition, the sun shelf edge tile markings shall comply with step edge requirements as provided in Section 454.1.2.5.3. SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.6 (3)	A sun shelf shall not protrude into the 15-foot (4572 mm) clearance requirement of Section 454.1.2.6. A sun shelf shall not protrude into the diving bowl. M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.1	Sun shelf areas must be a minimum of 20 inches (508 mm) wide and provide a minimum of 10 square feet (0.93 m ²) of horizontal surface adjoining on the edge of the pool (three sides of shelf must be surrounded by pool deck) over a distance of not less than 3 feet (914 mm). M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.1	The sun shelf edge that adjoins the pool edge must be continuous. M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.1	The sun shelf floor shall be horizontal or shall have uniform slope from a zero-depth entry, and its maximum depth shall be between 8" (203 mm) to 12" (254 mm) below the water surface. Note: Minimum Depth on a Horizontal sun Shelf Floor is 8" SHEET M1.1, STEP SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.2	Where a sun shelf is installed, wet deck located depth and no diving markers shall be placed every 20 feet (6096 mm) or less. M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.2	If the vertical distance between the coping or wet deck and the shelf floor adjacent to the wall is 12 inches (305 mm) or less, these markers shall indicate the water depth of the sun shelf. M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.2	All markers shall comply with Items 2, 6, and 7 of Section 454.1.2.3.1, except the distance between them as described in this section shall be followed. M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.3	For open gutter pools, where the gutter is used as a step, additional steps shall not be required where the distance from the gutter lip to the shelf floor is 10 inches or less.
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.2.8.3	At least one handrail must be provided at the sun shelf. The handrail shall be anchored into the bottom step and the sun shelf floor.

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Bristol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

		(Handrails and grabrails shall extend between 28 and 40 inches (711 mm and 1016 mm) above the sun shelf floor and deck) M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.2.8.4	Additional inlets shall be provided in the sun shelf area. The numbers and location shall be such as to ensure the volume of water in the shelf is filtered and chemically treated once every 60 minutes (1 hour) or less. SHEET M2.0, POOL MECHANICAL PLAN AND SUN SHELF FLOW DATA

POOL APPURTENANCES

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.1	Pool wet decks shall be constructed of concrete or other nonabsorbent material having a smooth slip resistant finish. Wet deck area finishes shall be designed for such use and shall be installed in accordance with the manufacturer's specifications. <i>Wooden decks and walkways are prohibited.</i> SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #8
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.1	Pool wet decks shall be uniformly sloped away from the pool or to deck drains to prevent standing water. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #8
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.2	The minimum slope for the wet deck is 2%, but in the portions of the deck intended to be accessible to disabled persons, it maybe 1% less than the maximum allowable cross slope given by the <i>Florida Building Code, Accessibility</i> . The maximum slope is 4%. A minimum of 1% deck slope is allowable for paver type decks. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #8
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.2	Textured deck finishes that provide pitting and crevices of more than 3/16 inch (4.8 mm) deep that accumulate soil are prohibited. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #8
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.2	If settling or weathering occurs that would cause standing water, the original slopes shall be restored, or corrective drains installed. ENSURE COMPLIANCE
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.3	Pool wet decks shall have a minimum unobstructed width of 4 feet (1,219 mm) around the perimeter of the pool, pool curb, ladders, handrails, diving boards, diving towers and slides. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #8
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.5	Walkways shall be provided between the pool and the sanitary facilities and shall be constructed of concrete or other nonabsorbent material having a smooth slip resistant finish for the first 15 feet (4,572 mm) of the walkway measured from the nearest pool water's edge. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.5	A hose bibb with a vacuum breaker shall be provided to allow the deck to be washed down with potable water. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.7	Food or drink service facilities shall not be located within 12 feet (3,658 mm) of the water's edge. SHEET I1.0, POOL NOTES #21
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.8	The vertical clearance above the pool deck shall be at least 7 feet (2,137 mm). SHEET I1.0, POOL NOTES #27

FENCE/BARRIER

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.9	All public pools shall be surrounded by a minimum 48 inch (1,219 mm) high fence or other approved substantial barrier. The fence shall be continuous around the perimeter of the pool area that is not otherwise blocked or obstructed by adjacent buildings or structures and shall adjoin with itself or abut to the adjacent members. Fencing consideration shall be given to the U.S. Consumer Product Safety Commission (CPSC) Publication, No. 362, March 2005, guidelines available from CPSC.gov; or Sections 454.2.17.1.1 through 454.2.17.1.8. Safety covers that comply with ASTM F1346-91 (Reapproved 2003), titled Safety Covers and Labeling Requirements for All Covers for Swimming Pools, Spas and Hot Tubs, and available from ASTM.org, do not satisfy this requirement. SHEET C1.0, OVERALL SITE PLAN AND SHEET M1.0, POOL GEOMETRY NOTES #9 & #10
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.9	If the self-closing, self-latching gate is also self-locking and is operated by a key lock, electronic opener or integral combination lock, then the operable parts of such locks or openers shall be 34 inches minimum (864 mm) and 48 inches maximum (1,219 mm) above the finished floor or ground. SHEET C1.0, OVERALL SITE PLAN AND SHEET M1.0, POOL GEOMETRY NOTES #9 & #10
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> A <input type="checkbox"/>	454.1.3.1.9	Doored access points from public rooms such as lobbies or club houses need not be through gates if the door(s) meet the same self-closing, self-latching requirements as a gate. Operable parts used for opening doors at these access points shall be 45 inches (1,143 mm) minimum to 48 inches (1,220 mm) maximum above the finish floor or ground. SHEET C1.0, OVERALL SITE PLAN AND SHEET M1.0, POOL GEOMETRY NOTES #9 & #10

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project: Bristol at Wylder Amenity Center Pool		Date: 1/31/2023
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.3.1.9	Gates shall open outward away from the pool area. SHEET C1.0, OVERALL SITE PLAN AND SHEET M1.0, POOL GEOMETRY NOTES #9 & #10
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.3.2	Pool coping shall not overhang into the pool more than 1½ inches (38 mm). ENSURE COMPLIANCE
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.3.3.1; 64E-9(3)(b)(c)(d)	All swimming pools shall be installed with a shepherd's hook securely attached to a one piece pole not less than 16 feet (4,880 mm) in length, and at least one 18-inch (457 mm) diameter lifesaving ring with sufficient rope attached to reach all parts of the pool from the pool deck. SHEET I1.0, POOL NOTES #19
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.3.3.1; 64E-9(3)(d)	Safety equipment shall be mounted in a conspicuous place and be readily available for use. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.3.3.1; 64E-9(3)(b)(c)	Pools greater than 50 feet (15,250 mm) in length shall have multiple units with at least one shepherd's hook and one life saving ring located along each of the longer sides of the pools SHEET C1.0, OVERALL SITE PLAN – TWO SETS REQUIRED
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.3.3.4	A room or space shall be provided for chemicals to be stored in a cool, dry, and well ventilated area under a roof and the area shall be inaccessible to the public. SHEET I1.0, POOL NOTES #11
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.4.1	Electrical equipment wiring and installation, including the bonding and grounding of pool components shall comply with Chapter 27 of the Florida Building Code, Building. Outlets supplying pool pump motors connected to single phase 120-volt through 240-volt branch circuits, whether by receptacle or by direct connection, and outlets supplying other electrical equipment and underwater luminaires operating at voltages greater than the low voltage contact limit, connected to single phase, 120-volt through 240-volt branch circuits, rated 15 or 20 amperes, whether by receptacle or by direct connection, shall be provided with ground fault circuit interrupter protection for personnel. *TO BE REVIEWED BY BUILDING DEPT.

LIGHTING

Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	454.1.4.2	Artificial lighting shall be provided at all swimming pools which are to be used at night or which do not have adequate natural lighting so that all portions of the pool, including the bottom, may be readily seen without glare. DH4159 PERMIT APPLICATION INDICATES NO NIGHTTIME SWIMMING
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	454.1.4.2.1	Outdoor pool lighting: Lighting shall provide a minimum of 3 footcandles (30 lux) of illumination at the pool water surface and the pool wet deck surface. Underwater lighting shall be a minimum of ½ watt incandescent equivalent, or 10 lumens, per square foot of pool water surface area. DH4159 PERMIT APPLICATION INDICATES NO NIGHTTIME SWIMMING
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	424.1.4.2.3	Underwater lighting: Underwater luminaires shall comply with Chapter 27 of the Florida Building Code, Building. *TO BE REVIEWED BY BUILDING DEPT.
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	454.1.4.2.3	The location of the underwater luminaires shall be such that the underwater illumination is as uniform as possible. DH4159 PERMIT APPLICATION INDICATES NO NIGHTTIME SWIMMING, (8) LIGHTS SHOWN INSTALLED, (FUTURE USE AFTER LIGHTING CERTIFICATION)
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	454.1.4.2.3	Underwater lighting requirements can be waived when the overhead lighting provides at least 15 footcandles (150 lux) of illumination at the pool water surface and pool wet deck surface. DH4159 PERMIT APPLICATION INDICATES NO NIGHTTIME SWIMMING
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.4.2.4	Overhead wiring. Overhead service wiring shall not pass within an area extending a distance of 10 feet (3,048 mm) horizontally away from the inside edge of the pool walls, diving structures, observation stands, towers or platforms. Allowances for overhead conductor clearances to pools that meet the safety standards in the <i>National Electrical Code</i> may be used instead. Electrical equipment wiring and installation including the grounding of pool components shall comply with Chapter 27. SHEET I1.0, POOL NOTES #30
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.4.2.5	Voltage limitation. Underwater lighting, or lighting that may be exposed to nozzle directed pool water, shall not exceed 30 volts DC or 15 volts AC. Such lights shall be installed in accordance with manufacturer's specifications and approved for such use by UL or NSF. *TO BE REVIEWED BY BUILDING DEPT.

EQUIPMENT AREA

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.1	Equipment designated by the manufacturer for outdoor use may be located in an equipment area, all other equipment must be located in an equipment room or enclosure. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.1, 454.1.6.4, &	Plastic pipe subject to a period of prolonged sunlight exposure must be coated to protect it from ultraviolet light degradation. SHEET I1.0, POOL NOTES #5

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Bristol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

	454.1.6.5.6	
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.1	An equipment area shall be surrounded with a fence at least 4 feet (1,219 mm) high on all sides not confined by a building or equivalent structure. A self-closing and self-latching gate with a permanent locking device shall be provided if necessary, for access. An equipment room shall be protected on at least three sides and overhead. Any fence or gate installed shall use members spacing that shall not allow passage of a 4-inch (102 mm) diameter sphere. The fourth side may be a gate, fence, or open if otherwise protected from unauthorized entrance. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.1	An equipment enclosure shall be lockable or otherwise protected from unauthorized access. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.3.1.9	A latched, lockable gate shall be placed in the fence within 10 feet (3,048 mm) of the closest point between the pool and the equipment area for service access. SHEET C1.0, OVERALL SITE PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.3	The equipment enclosure, area or room floor shall be of concrete or other nonabsorbent material having a smooth slip resistant finish and shall have positive drainage, including a sump pump if necessary SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.4	Equipment rooms shall have either forced draft or cross ventilation. SHEET M4.2, FILTER EQUIPMENT PLAN, (2) VENTS
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.5	The opening to an equipment room or area shall be a minimum 3 feet by 6 feet (914 mm by 1829 mm) and shall provide easy access to the equipment. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.5	Below grade collector tank(s) must have adequate access for cleaning, maintenance and inspection. SHEET M4.2, COLLECTOR TANK DETAILS
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.6	The size of the equipment enclosure, room or area shall provide working space to perform routine operations. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.6	Clearance shall be provided for all equipment as prescribed by the manufacturer to allow normal maintenance operation and removal without disturbing other piping or equipment. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.7	The equipment room is lighted to provide a minimum 30 fc (300 lux) of illumination at floor level. SHEET M4.2, FILTER EQUIPMENT PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.8	Equipment enclosures, rooms or areas shall not be used for storage of chemicals emitting corrosive fumes or for storage of other items to the extent that entrance to the room for inspection or operation of the equipment is impaired. ENSURE COMPLIANCE
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.5.9	A hose bibb with vacuum breaker shall be located in the equipment room or area. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN

SANITARY FACILITIES

Y☒N□N/A□	454.1.6.1	<p>Sanitary facilities: The entry doors of all restrooms shall be located within a 200-foot (60,960 mm) walking distance of the nearest water's edge of each pool served by the facilities.</p> <p>Exception: Where a swimming pool serves only a designated group of residential dwelling units including hotel rooms and not the general public, poolside sanitary facilities are not required if all living units are within a 200-foot (60,960 mm) horizontal radius of the nearest water's edge, are not over three stories in height unless serviced by an elevator, and are each equipped with private sanitary facilities. SHEET C1.0, OVERALL SITE PLAN</p>																																				
Y☒N□N/A□	454.1.6.1	<p>Sanitary facilities: Pools with a bathing load larger than 40 persons shall provide separate sanitary facilities labeled for each sex SHEET C1.0, OVERALL SITE PLAN</p>																																				
Y☒N□N/A□	454.1.6.1.1	<p>Sanitary facilities: Required fixtures shall be provided as indicated on Table 454.1.6.1. The fixture count on this chart is deemed to be adequate for the pool and pool deck area that is up to three times the area of the pool surface provided. When multiple fixture sets are required and separate facilities are provided for each sex, the fixtures used in ancillary family style restrooms can be used to meet the requirements of this section. (PS) 2,494 SQ.FT. X (3) = 7,482 SQ.FT.</p>																																				
Y☒N□N/A□	454.1.6.1.1	<table><tr><th colspan="8">TABLE 454.1.6.1</th></tr><tr><th colspan="8">PUBLIC SWIMMING POOL—REQUIRED FIXTURE COUNT</th></tr><tr><th rowspan="2">REQUIRED MINIMUM FIXTURE COUNT</th><th>SIZE OF POOL (square feet)</th><th colspan="3">MEN'S RESTROOM</th><th colspan="2">WOMEN'S RESTROOM</th></tr><tr><th>For SI: 1 FT² = 0.0929 m².</th><th>Urinals</th><th>WC</th><th>Lavatory</th><th>WC</th><th>Lavatory</th></tr><tr><td>ENSURE → ☒</td><td>0 – 2,500</td><td>1</td><td>1</td><td>1</td><td>1</td><td>1</td></tr></table>	TABLE 454.1.6.1								PUBLIC SWIMMING POOL—REQUIRED FIXTURE COUNT								REQUIRED MINIMUM FIXTURE COUNT	SIZE OF POOL (square feet)	MEN'S RESTROOM			WOMEN'S RESTROOM		For SI: 1 FT² = 0.0929 m².	Urinals	WC	Lavatory	WC	Lavatory	ENSURE → ☒	0 – 2,500	1	1	1	1	1
TABLE 454.1.6.1																																						
PUBLIC SWIMMING POOL—REQUIRED FIXTURE COUNT																																						
REQUIRED MINIMUM FIXTURE COUNT	SIZE OF POOL (square feet)	MEN'S RESTROOM			WOMEN'S RESTROOM																																	
	For SI: 1 FT² = 0.0929 m².	Urinals	WC	Lavatory	WC	Lavatory																																
ENSURE → ☒	0 – 2,500	1	1	1	1	1																																

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

		<input type="checkbox"/>	2,501 – 5,000	2	1	1	5	1
		<input type="checkbox"/>	5,001 – 7,500	2	2	2	6	2
		<input type="checkbox"/>	7,501 – 10,000	3	2	3	8	3
TABLE NOTE:	454.1.6.1.1	Square footage of interactive water features (IWF's) is required to be included when calculating the size of pool for the purposes of determining the type and number of fixtures for the sanitary facilities. For those facilities with an IWF in addition to the pool, causing the combined pool size square footage to exceed the threshold required category fixture count, a unisex restroom may be installed to satisfy the fixture requirement for every additional 1,250 square feet or fraction thereof. The IWF feature flow for one unisex restroom shall not exceed 100 gpm, nor shall bathing load exceed 20 patrons.						
NOTE:	454.1.6.1.1	Exception: When a public swimming pool meets all of the following conditions the following shall apply: 1. The pool serves only a designated group of dwelling units, 2. The pool is not for the use of the general public, and 3. A building provides sanitary facilities; The fixture requirement for the building shall be determined and if it exceeds the requirement in Table 454.1.6.1 then the building requirement shall regulate the fixture count, otherwise the fixture count shall be based on the requirement for the pool. Under no circumstances shall the fixture counts be cumulative.						
Y☒N□N/A□	454.1.6.1.1	Sanitary facilities: One diaper changing table shall be provided at each restroom. Diaper changing tables are not required at restrooms where all pools served are restricted to adult use only. (Swim diapers are recommended for use by children that are not toilet trained. Persons that are ill with diarrhea cannot enter the pool.) SHEET C1.0, OVERALL SITE PLAN – ENSURE COMPLIANCE						
Y☒N□N/A□	454.1.6.1.2	Sanitary facilities: Outside access to facilities shall be provided for bathers at outdoor pools. Where the restrooms are located within an adjacent building and the restroom doors do not open to the outside, the restroom doors shall be within 50' (15,240 mm) of the building's exterior door. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #26						
Y☒N□N/A□	454.1.6.1.2	Sanitary facilities: If the restrooms are not visible from any portion of the pool deck, signs shall be posted showing directions to the facilities. Directions shall be legible from any portion of the pool deck; letters shall be a minimum of 1" (25 mm) high. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #26						
Y☒N□N/A□	454.1.6.1.3	Sanitary facilities: Floors of sanitary facilities shall be constructed of concrete or other nonabsorbent materials, shall have a smooth, slip resistant finish, and shall slope to floor drains, which must be installed within the facility. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #26						
Y☒N□N/A□	454.1.6.1.3	Sanitary facilities: There are no foot baths, carpet or duck boards on the floor. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #26						
Y☒N□N/A□	454.1.6.1.3	Sanitary facilities: The intersection between the floor and walls shall be covered where either floor or wall is not made of waterproof materials such as tile or vinyl. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #26						
Y☒N□N/A□	454.1.6.1.4	Sanitary facilities: A hose bibb with vacuum breaker is in or within 25' (7,620 mm) each restroom for ease of cleaning. SHEET C1.0, OVERALL SITE PLAN AND SHEET I1.0, POOL NOTES #26						
RECIRCULATION AND TREATMENT								
Y☒N□N/A□	454.1.6.2	A minimum of one rinse shower shall be provided on the pool deck of all outdoor pools within the perimeter of the fence. SHEET I1.0, POOL NOTES #7 (SHOWER NOT LOCATED ON OVERALL SITE PLAN – ENSURE COMPLIANCE)						
Y☒N□N/A□	454.1.6.3	An atmospheric break or approved backflow prevention device shall be provided in each pool water supply line that is connected to a public water supply. ENSURE COMPLIANCE, PORT ST. LUCIE UTILITIES						
Y☒N□N/A□	454.1.6.3	Vacuum breakers shall be installed on all hose bibbs. ENSURE COMPLIANCE						
Y☒N□N/A□	454.1.6.5.1	Recirculation and treatment equipment such as filters, recessed automatic surface skimmers, ionizers, ozone generators, disinfection feeders and chlorine generators shall be tested and approved using the NSF/ANSI Standard 50, Circulation System Components and Related Materials for Swimming Pool, Spas/Hot Tubs, dated April 2007, which is incorporated by reference.						

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.2	The recirculation system shall be designed to provide a minimum of four turnovers of the pool volume per day. Pools that are less than 1,000 square feet (93 m ²) at health clubs shall be required to provide eight turnovers per day. 58,860 GALLS ÷ 335GPM ÷ 60 = 2.92 HOURS
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	64E-9.004(5)	The pool recirculation system must be operated at all times when the pool is open for use. The recirculation system may be shut off three hours after the pool closes but must resume operation three hours before opening the pool. Shut down time must be controlled by a time clock. When a variable speed pump is used, the recirculation system shall be operated such that it achieves the equivalent of 6 hours of treatment at 100% design flowrate during the daily closed period, or at least one complete water volume turnover, whichever is greater. Exception: vacuum DE systems are excluded from this allowance. ***If multiple recirculation pumps are used the required flowrate, filtration, & chemical treatment must be maintained to operate the pool. Example: The pool must not be open to the public without one pump if the additional pumps are not able to maintain the proper flowrate, filtration, and chemical treatment (some type of audible alarming may be employed to ensure requirement is met). ENSURE COMPLIANCE
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	64E-9.004(1)	Pool makeup water supply is from an approved potable water system or meets those requirements with bacteriological/chemical reports to county health department. ENSURE COMPLIANCE – ST. LUCIE COUNTY
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.4	If the pump or suction piping is located above the water level of the pool, the pump shall be self-priming. SHEET M4.2, FILTER EQUIPMENT LIST, SPECK, MODEL NB 65/250, 10HP
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.4	Pumps that take suction prior to filtration shall be equipped with a hair and lint strainer. SHEET M4.2, FILTER EQUIPMENT LIST, SPECK, MODEL NB 65/250, 10HP
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.4	Pressure filter system pump shall be selected to provide the required recirculation flow against a minimum total dynamic head of 60 feet (18,288 mm) unless hydraulically justified by the design engineer. SHEET M4.2, FILTER EQUIPMENT LIST, SPECK, MODEL NB 65/250, 10HP, PUMP RATED AT 360GPM @ 80ftTDH, REGULATE TO 335GPM
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.5	Filters are sized to handle the required recirculation flowrate. SHEET I1.1, POOL EQUIPMENT LIST, (3) HAYWARD, MODEL HCF340, 42' DIA. SAND FILTERS = 28 SQ.FT.

GUTTER SYSTEMS

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3	The design pattern of recirculation flow of pool with perimeter overflow system (gutters) is 100% through main drain piping and 100% through perimeter overflow system piping. SHEET M2.0, POOL MECHANICAL PLAN, MAIN DRAIN & GUTTER = 8" (470GPM MAX FLOW)
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1	The lip of the gutter shall be uniformly level with a maximum tolerance of ¼" (6 mm) between the high and low areas. SHEET M1.1, TYPICAL WALL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1	The bottom of the gutter shall be level or slope to the drains. SHEET M1.1, TYPICAL WALL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1	The spacing between drains shall not exceed 10 feet (3,048 mm) for 2-inch (51 mm) drains or 15 feet (4,572 mm) for 2½-inch (64 mm) drains, unless hydraulically justified by the design engineer. SHEET I1.0, POOL NOTES #14
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.1	Either recessed type or open type gutters shall be used. Special designs can be approved provided they are within limits of sound engineering practice. SHEET M1.1, TYPICAL WALL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.1	Open type gutters shall be at least 6 inches (150 mm) deep and 12 inches (305 mm) wide. SHEET M1.1, TYPICAL WALL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.1	The gutter shall slope 2 inches (51 mm), +/- ¼ inch (+/- 6 mm), from the lip to the drains. SHEET M1.1, TYPICAL WALL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.1	The gutter drains shall be located at the deepest part of the gutter. SHEET M1.1, TYPICAL WALL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.2	All gutter systems shall discharge into a collector tank. SHEET M2.0, POOL MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.3	The gutter lip shall be tiled with a minimum of 2" (51 mm) tile on the pool wall, each a minimum size of 1" (25 mm) on all sides. Exception: Stainless steel gutter systems when it can be shown that the surfaces at the waterline and back of the gutter are easily cleanable. SHEET M1.1, TYPICAL WALL SECTION
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.3	All tile used on the flat, horizontal part, or the leading edge of an open-type gutter, must be slip resistant. SHEET M1.1, TYPICAL WALL SECTION – EXPOSED AGGREGATE

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.3.1.3	The back vertical wall of the gutter shall be tiled with glazed tile. Exception: Stainless steel gutter systems when it can be shown that the surfaces at the waterline and back of the gutter are easily cleanable. SHEET M1.1, TYPICAL WALL SECTION
SAND FILTER SYSTEMS		
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.5.1	Sand type filters: The filter is sized such that the filtration rate does not exceed 3 gpm/FT ² for rapid sand filter or 15 gpm/FT ² for high rate sand filters (or 20 if so rated by NSF). SHEET I1.1, POOL EQUIPMENT LIST, (3) HAYWARD, MODEL HCF340, 42' DIA. SAND FILTERS = 28 SQ.FT. X 15GPM = 430GPM MAX FLOW
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.5.2.1	Sand type filters: Pressure filter systems shall be equipped with an air relief valve, influent and effluent pressure gauges with minimum face size of 2 inches (51 mm) reading 0–60 psi (0–414 kPa), and a sight glass when a backwash line is required. SHEET I1.1, POOL EQUIPMENT LIST, ENSURE COMPLIANCE
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.8	Sand type filters: The filter and vacuuming system shall have the necessary valves and piping to allow filtering to pool, vacuuming to waste, vacuuming to filter, complete drainage of the filter tank, backwashing for sand and pressure. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN
PIPING		
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.6	All plastic pipe used in the recirculation system shall be imprinted with the manufacturer's name and the NSF-pw logo for potable water applications. Size, schedule and type of pipe shall be included on the drawings. SHEET I1.0, POOL NOTES #5
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.7	Return line, main drain line, and surface overflow system lines each have proportioning valves. SHEET M3.0, POOL EQUIPMENT MECHANICAL AREA PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.8	All pressure piping is sized such that the flow velocity does not exceed 10' per second (2,038 mm/s) at the design flow rate. (Exception: Precoat lines when higher velocity is needed for agitation purposes.) 4" = 392GPM MAX FLOW/DESIGN FLOW 335GPM
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.8	All suction piping is sized such that the flow velocity does not exceed 6' per second (1,829 mm/s) at the design flow rate. (Exception: Vacuum filter header assembly where velocity may be up to 10' per second (3,048 mm/s).) 6" = 529GPM MAX FLOW/DESIGN FLOW 335GPM
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.8	Main drain systems and surface overflow systems which discharge to collector tanks are sized such that the flow velocity does not exceed 3' per second (914 mm/s) at the design flow rate. 8" = 470GPM MAX FLOW/DESIGN FLOW 335GPM
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.9	Floor return inlets have a means of flow adjustment. SHEET M4.0, FLOOR INLET DETAIL
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.9; 454.1.6.5.9.5	Floor inlets shall be designed and installed such that they do not protrude above the pool floor and all inlets shall be designed and installed so as not to constitute sharp edges or protrusions hazardous to pool bathers. SHEET M4.0, FLOOR INLET DETAIL
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.9.4	Pools greater than 30 feet (9,144 mm) in width shall have either floor inlets only, or a combination of floor inlets and wall inlets. Pools with floor inlets only shall have a number of floor inlets provided such that the spacing between adjacent inlets does not exceed 20 feet (6,096 mm) and the spacing between inlets and an adjacent wall does not exceed 10 feet (3,048 mm). SHEET M2.0, POOL MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.9.6	The flow rate through each inlet shall not exceed 20 gpm (1 L/s) except for inlets designed for higher flows as specified by the manufacturer. SHEET M2.0, POOL MECHANICAL PLAN, (22) INLETS – 335GPM ÷ 22 = 15.22GPM EACH
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10	Main drain outlets: All pools shall be provided with an outlet at the deepest point. SHEET M1.0, POOL GEOMETRY PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10.1	If the depth at the outlet deviates more than 3 inches (76 mm) from the side wall, that depth shall be identified on depth markers in addition to the markers normally required for the sidewall depth. Markers for the depth at the drains shall be in accordance with Section 454.1.2.3 with the following words added: "AT CENTER" for circular areas and "AT DEEP POINT" for other pool shapes. SHEET M1.0, POOL GEOMETRY PLAN AND SHEET I1.0, POOL NOTES #3
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10.2	Outlets are covered by a secure grate which requires the use of a tool to remove. SHEET M4.0, MAIN DRAIN DETAIL
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10.2	The open area of the main drain grate(s) is such that the maximum velocity of water passing through the openings does not exceed 1½ feet per second (457 mm/s) at 100% of the design recirculation flow. SHEET I1.1, POOL EQUIPMENT LIST

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10.2	Main drain covers/grates shall comply with the requirements of ANSI/APSP 16 and the water velocity of this section. SHEET I1.1, POOL EQUIPMENT LIST, (2) AQUASTAR, MODEL 12xxx, MAX FLOW 360GPM EACH
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10.4	If the area is subject to high ground water, the pool shall be designed to withstand hydraulic uplift or shall be provided with hydrostatic relief devices. SHEET M4.0, MAIN DRAIN DETAIL
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10.5	The main drain outlet shall be connected to a collector tank. SHEET M2.0, POOL MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.10.5	The capacity of the collector tank shall be at least 1 minute of the recirculated flow unless justified by the design engineer. Note: Vacuum filter tanks are considered collector tanks. SHEET I1.1, POOL EQUIPMENT LIST, 350 GALLON CAPACITY
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1 Definitions	<p>“Collector tank” means a reservoir, with a minimum of 2.25 square feet (0.2 m²) water surface area, that is vented by piping and/or open to the atmosphere, from which the recirculation or feature pump takes suction, which receives the gravity flow from the main drain line and surface overflow system or feature water source line, and that is cleanable.</p> <p>The vent shall measure a minimum of 12.56 square inches (8,103 mm²) in area and shall be equipped with a screen, or equivalent device, to prohibit entry by animals. The vent shall be designed to minimize rainwater entry into the tank. Tanks with vented lids shall not be required to be equipped with a separate vent. Tanks shall be constructed of concrete or other impervious and structurally rigid material, with adequate manway access, shall be watertight, shall be free from structural cracks and shall have a nontoxic smooth finish. SHEET M4.2, COLLECTOR TANK DETAILS</p>
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.11	<p>An automatic and manual water makeup control shall be provided to maintain the water level at the lip of the overflow gutter or at the mouth of the recessed automatic surface skimmers and shall discharge through an air gap into a fill pipe or collector tank.</p> <p><i>Over the rim fill spouts are prohibited.</i> SHEET M4.2, COLLECTOR TANK DETAILS</p>
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.12	<p>A portable, robotic or plumbed in vacuum cleaning system shall be provided.</p> <p>Note: Cleaning devices shall not be used while the pool is open to bathers. SHEET I1.0, POOL NOTES #36</p>
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.12	All vacuum pumps shall be equipped with hair and lint strainers. SHEET I1.0, POOL NOTES #36
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.13	A rate of flow indicator (flowmeter), reading in gpm, shall be installed on the return line. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN
Y <input type="checkbox"/> N <input checked="" type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.13	<p>The rate of flow indicator shall be properly sized for the design flow rate and shall be capable of measuring from one half to at least one and one-half times the design flow rate. SHEET I1.1, POOL EQUIPMENT LIST, BLUE-WHITE, 4”, MODEL F30400P, 75GPM – 420GPM RANGE, 168GPM – 503GPM REQUIRED, FLOW METER UNDERSIZED</p>
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.13	The clearances upstream and downstream from the rate of flow indicator shall comply with manufacturer’s installation specifications. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	64E-9.004(e)	<p>Landscape irrigation water that wets the wet deck area of the pool, the pool itself, enters the collector tank, or wets an interactive water feature must be potable water from a public water system or shall meet the bacteriological quality of potable water as evidenced by annual laboratory analysis submitted to the department. Reclaimed water may not be used in these areas. If reclaimed water is used in the vicinity of the pool (inside of the pool fence or within 100’ of the pool water’s edge) it must employ drip irrigation or soaker hoses. Signs shall be posted notifying pool patrons that reclaimed water is in use and is not to be consumed. ENSURE COMPLIANCE</p>

ZERO DEPTH ENTRY POOLS

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.9.6.1	Zero depth entry pools shall have a continuous floor slope from the water edge to 3 feet (914 mm) of water depth at which point the slope can transition to another, less steep continuous slope. Floating safety ropes and slope transition markings are not required at this transition point. SHEET M1.1, POOL SECTION,
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.9.6.2	The deck level perimeter overflow system with grate shall be provided at the water’s edge across the entire zero depth portion of the pool. Zero entry grate must be 8 to 12 inches wide, slip resistant, and constructed for intended purpose of submersion in water and exposure to UV sunlight. SHEET M1.1, ZERO ENTRY SECTION,
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.9.6.3	The pool deck may slope toward the pool for no more than 7 feet (2,133 mm), as measured from the overflow system grate outward. Beyond this area the deck shall slope away from the pool in accordance with Section 454.1.2.2.3. SHEET M1.1, ZERO ENTRY SECTION,

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.9.6.4	"No Entry, Shallow Water" signs shall be provided along the pool wall edge where the water depth is less than 3 feet (914 mm) deep. No entry signs shall be slip resistant, shall have 4-inch-high (102 mm) letters, shall be located within 2 feet (610 mm) of the pool edge and shall be spaced no more than 15 feet (4,572 mm) apart. SHEET M1.0, POOL GEOMETRY PLAN AND GEOMETRY PLAN NOTES #16
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.9.6.5	Additional inlets shall be provided in areas of less than 18 inches (457 mm) deep. The numbers and location shall be such as to double the flow rate into this area. SHEET M2.0, POOL MECHANICAL PLAN
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.9.6.6	Min. 1 turnover every 2 hours in areas 3' (914 mm) deep or less. >3' (914 mm) area has max. 6-hour turnover rate. SHEET M2.0, POOL MECHANICAL PLAN AND ZERO ENTRY FLOW DATA
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.9.6.6	The design plans submitted by the applicant provide the volume of water in the pool area of 3' (914 mm) depth and less, the volume of water in the pool area greater than 3' (914 mm) in depth and the total volume in the pool for determination of minimum circulation flow. The volume calculations shall provide verification that the correct volume of water is used to determine the minimum flow at the 2-hour and the 6-hour flow requirements. SHEET M2.0, POOL MECHANICAL PLAN AND ZERO ENTRY FLOW DATA
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	454.1.9.6.7	Those portions of the zero-depth entry pool, where the water depth will not allow for the proper installation of underwater lighting, shall be provided with 6 foot-candles (60 lux) of lighting on the deck and the water. DH4159 PERMIT APPLICATION INDICATES NO NIGHTTIME SWIMMING

POOL WASTEWATER

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.15	Pool wastewater shall be discharged through an air gap. SHEET I1.0, POOL NOTES #6
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.15	Pool wastewater disposal shall be to sanitary sewers, storm sewers, drain fields, or by other means, in accordance with local requirements including obtaining all necessary permits. SHEET I1.0, POOL NOTES #6
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.15	All lines shall be sized to handle the expected flow. SHEET M4.2, FILTER EQUIPMENT LIST, ROLACHEM, MODEL RC103, 38GPD, 4" MINIMUM PIPE SIZE
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.15	There shall not be a direct physical connection between any drain from a pool or recirculation system and a sewer line. SHEET M4.2, WASTE LINE DETAIL

ADDITION OF CHEMICALS

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.8.12	Automated ORP & PH controllers are provided *Required for all pools where the turnover rate is less than 3 hours, spa pools, and all pools categorized under FBC 454.1.9. SHEET M4.2, FILTER EQUIPMENT LIST, HAYWARD, CAT2000 pH/ORP CONTROLLER
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.18	Only NSF 60 approved chemicals shall be provided. SHEET I1.0, POOL NOTES #33
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	64E-9.004(9)	A test kit is provided and is capable of testing for free active halogens, total or combined available chlorine, total alkalinity, calcium hardness & pH. SHEET I1.1, MAINTENANCE EQUIPMENT LIST, TAYLOR, MODEL K-2005
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16	Disinfection and pH adjustment shall be added to the pool recirculation flow using automatic feeders meeting the requirement of ANSI/NSF 50.
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16	All chemicals shall be fed into the return line after the pump, heater and filters unless the feeder was designed by the manufacturer and approved by the NSF to feed to the collector tank or to the suction side of the pump. SHEET M3.0, POOL EQUIPMENT AREA MECHANICAL PLAN

HYPOHALOGENATION AND ELECTROLYTIC CHLORINE GENERATORS

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.2	Hypohalogenation: The hypohalogenation-type feeder and electrolytic chlorine generators shall be adjustable from 0 to full range. SHEET M4.2, FILTER EQUIPMENT LIST, ROLACHEM, MODEL RC503, 77GPD
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.2	Hypohalogenation: The feeder is capable of feeding a dosage of 6 ppm to the minimum required turnover flow rate (if solution type feeders, a 5% calcium hypochlorite or 10% sodium hypochlorite solution). 335GPM ÷ 13.87 = 24.15 GPD
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.2	Hypohalogenation: An electrical feeder, when used, has electrical interlock with the recirculation pump to prevent the disinfectant from siphoning or feeding directly into the pool or pool piping under any type failure of the recirculation equipment. A flow sensor controller may be used. SHEET M4.2, FILTER EQUIPMENT NOTES #1

PLANS REVIEW CHECKLIST – PUBLIC SWIMMING POOL –DOH / BOAF version December 31, 2020 (Effective January 1, 2021)

Project:	Brystol at Wylder Amenity Center Pool	Date:	1/31/2023
-----------------	--	--------------	------------------

Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.2	Hypohalogenation: Solution crock has a volume equal to at least 50% of the maximum daily feed capacity of the chlorine solution feeder. Solution crock is marked to indicate contents. SHEET M4.2, FILTER EQUIPMENT LIST, (2) 100 GALLON CAPACITY
FEEDER FOR pH ADJUSTMENT		
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.3	Feeders for pH adjustment shall be provided on all pools.
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.3	pH adjustment feeder: pH adjustment feeders shall be positive displacement type, shall be adjustable from 0 to full range. SHEET M4.2, FILTER EQUIPMENT LIST, ROLACHEM, MODEL RC103, 38GPD
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.3	pH adjustment feeder: An electrical feeder has electrical interlock with the recirculation pump to prevent discharge when the recirculation pump is not operating. SHEET M4.2, FILTER EQUIPMENT NOTES #1
Y <input checked="" type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.6.5.16.3	pH adjustment feeder: The solution crock volume is at least 50% of the maximum daily capacity of the feeder and is marked to indicate the contents. SHEET M4.2, FILTER EQUIPMENT LIST, 65 GALLON CAPACITY
ELECTRICAL *TO BE REVIEWED BY BUILDING DEPT.		
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.10.4.1	Ground fault circuit interrupter protection for personnel. Outlets supplying repaired, replaced, altered, or relocated pool pump motors connected to single-phase, 120-volt through 240-volt branch circuits, whether by receptacle or by direct connection, and outlets supplying all other repaired, replaced, altered, or relocated electrical equipment and underwater luminaires operating at voltages greater than the low voltage contact limit, connected to single-phase, 120-volt through 240-volt branch circuits, rated 15 and 20 amperes, whether by receptacle or by direct connection, shall be provided with ground fault circuit interrupter protection for personnel.
EQUIPOTENTIAL BONDING *TO BE REVIEWED BY BUILDING DEPT.		
Y <input type="checkbox"/> N <input type="checkbox"/> N/A <input type="checkbox"/>	454.1.10.4.2	Equipotential bonding. Any of the parts specified in Sections 680.26(B)(1) through(B)(7) of the NFPA 70, National Electrical Code that are repaired, replaced, altered, or installed new at an existing swimming pool shall be connected to the existing bonding system using solid copper conductors, insulated, covered, or bare, not smaller than 8 AWG or with rigid metal conduit of brass or other identified corrosion resistant metal. Connections to bonded parts shall be made in accordance with Section 250.8 of NFPA 70, <i>National Electrical Code</i> . An 8 AWG or larger solid copper bonding conductor provided to reduce voltage gradients in the pool area shall not be required to be extended or attached to remote panelboards, service equipment, or electrodes. All metallic float in light rings shall be connected to the equipotential bonding grid. Float in light rings with no provision for bonding, and other devices which do not provide an electrical connection between a metallic underwater luminaire and the forming shell of a wet niche fixture, including screws or bolts not supplied by the luminaire's manufacturer and listed for use with the specific luminaire, shall not be allowed for use with any underwater luminaire that is required to be grounded. Where none of the bonded parts is indirect connection with the pool water, the pool water shall be in direct contact with an approved corrosion resistant conductive surface that exposes not less than 9 square inches (5800 mm ²) of surface area to the pool water at all times. The conductive surface shall be located where it is not exposed to physical damage or dislodgement during usual pool activities, and it shall be bonded in accordance with Section 680.26(B) of the NFPA 70, <i>National Electrical Code</i> . A bonded concrete pool shell shall be considered to be a conductive surface. The interior metallic surface or surfaces of any forming shell (wet niche) shall not be covered with any material, including plaster, except potting compound covering internal bonding connections in conformance with 680.23(B)(2)(b) of NFPA 70, <i>National Electrical Code</i> , shall be allowed.